



TC - 5945

**POLLUCON** LABORATORIES PVT. LTD.

QR/7.8/01

Test Report

ULR No : TC59452400002447F

Page 1 of 1

Customer's Name and Address :

**MAHATMA GANDHI MEMORIAL EDUCATION SOCIETY
SARVAJANIK VIDYALAY
DAMAN**Test Report No : **PLPL/W/24/02/22/0166**
Issue Date : **27/02/2024**
Customer's Ref. : **Verbal**Description of Sample : **Water**Qty / Nos of Sample : **01 Ltr / 01**Date of Sampling : **22/02/2024**Protocol / Purpose : **Quality Check**Sample Receipt Date : **22/02/2024**Sampling : **Not Applicable**Packing / Seal : **Sealed**Lab ID : **PLPL/W/24/02/22/0166**Date of Starting of Test : **22/02/2024**Date of Completion : **27/02/2024**Sampling By : **Pollucon Team**Identification of Sample # : **DMC Water****RESULT TABLE**

S.NO	TEST PARAMETER	UNIT	RESULT	TEST METHOD
1	Odour	--	Agreeable	IS 3025 (Part 5) 2018
2	Colour	Hazen	2	IS 3025 (Part 4) 2018
3	Taste	--	Agreeable	IS 3025 (Part 8) 2023
4	pH	--	7.24	IS 3025 (Part 11) 2022
5	Turbidity	NTU	0.06	IS 3025 (Part 10) 2022
6	Total Dissolved Solids	mg/L	98	IS 3025 (Part 16) 2023
7	Total Hardness as CaCO ₃	mg/L	26	IS 3025 (Part 21) 2019
8	Chloride	mg/L	17.49	IS 3025 (Part 32) 2019
9	Fluoride	mg/L	Not Detected	APHA (23rd Edition) 4500 F D 2017
10	Iron as Fe	mg/L	Not Detected	APHA (23rd Edition) 3500 Fe B 2017
11	Coliforms	/100 ml	Absent	APHA (23rd Edition) 9221 D 2017
12	Escherichia coli	/100 ml	Absent	IS 1622 2019

Detection Limit:- Fluoride: < 0.05, Iron as Fe: < 0.05

Note : Sample found conforming as per IS 10500:2012 standard for the tested parameters.

*mali***Dr. Maheshwari Solanki**
Sr Chemist*Sweety***Ms. Sweety Jain**
Sr. Microbiologist*Dr. Arun Bajpai***Dr. Arun Bajpai**

Authorised Signatory

Note : This Report is subject to terms & conditions mentioned overleaf (# : Details given by Customer)
 • Recognition under E.P. Act 1986 MoEF/CPCB • GPCB Approved • ISO 14001 • ISO 45001 • ISO 9001 • Details given by Customer & Drug Control
 Schedule II Auditor *** End of Report *** Administration [FDA]-Gujarat

"Pollucon House", Plot No. 5 & 6, Opp.Balaji Industrial Society, Navjivan Circle, Udhana Magdalla Road, Surat-395007, Gujarat, India.

Phone : 0261-2635750, 0261-2635751, 0261-2635775, 07016605174, WEB: www.polluconlab.com, E. mail: pollucon@gmail.com