



POLLUCON LABORATORIES PVT. LTD.

TC-14227

Test Report

QF/7.8/01
ULR No : TC142272500005695F
Page 1 of 1

Customer's Name and Address :

SARVAJANIK VIDYALAYA DAMAN MAHATMA GANDHI MEMORIAL EDUCATION SOCIETY'S SARVAJANIK VIDYALAYA, DAMAN. SURVEY NO. 544/2, KHARIWAD , NANI DAMAN.	Test Report No : PLPL/W/25/04/15/0053 Issue Date : 21/04/2025 Customer's Ref. : Verbal
---	---

Description of Sample : Water	Qty / Nos of Sample : 01 Ltr / 01
Date of Sampling : 15/04/2025	Protocol / Purpose : Quality Check
Sample Receipt Date : 15/04/2025	Sampling Procedure : Not Applicable
Packing / Seal : Sealed	Lab ID : PLPL/W/25/04/15/0053
Date of Starting of Test : 15/04/2025	Date of Completion : 21/04/2025
Sampling By : Pollucon Team (Keyur Desai)	
Identification of Sample # : RO Water	

RESULT TABLE

S.NO	TEST PARAMETER	UNIT	RESULT	DESIRABLE LIMIT AS PER IS 10500 : 2012	TEST METHOD
1	Odour	--	Agreeable	Agreeable	IS 3025 (Part 5)
2	Colour	Hazen	LTAR(<1)	Max 5	IS 3025 (Part 4) Clause.5
3	Taste	--	Agreeable	Agreeable	IS 3025 (Part 8)
4	pH	--	7.01	6.5 to 8.5	IS 3025 (Part 11) Clause.2
5	Turbidity	NTU	LTAR(<0.02)	Max 1	IS 3025 (Part 10)
6	Total Dissolved Solids	mg/L	98	Max 500	IS 3025 (Part 16)
7	Total Hardness as CaCO ₃	mg/L	21	Max 200	IS 3025 (Part 21) Clause.5
8	Chloride	mg/L	18.99	Max 250	IS 3025 (Part 32) Clause.2
9	Fluoride	mg/L	LTAR(<0.05)	Max 1	APHA (24th Edition) 4500 F D
10	Iron as Fe	mg/L	LTAR(<0.05)	Max 1	APHA(24th Edition) 3500 Fe B
11	Coliforms	/100 ml	Absent	Absent	IS 15185
12	Escherichia coli	/100 ml	Absent	Absent	IS 15185

Note : LTAR :- Lower Than Accreditation Range

Note : Sample found conforming as per IS 10500:2012 standard for the tested parameters.

Dr. Maheshwari Solanki
Sr Chemist

Dr. Harshal Gandhi
Sr. Microbiologist

Dr. Arun Bajpai
Authorized Signatory

Note : This Report is subject to terms & conditions mentioned overleaf. (# : Details given by Customer)

● Recognised Env. Lab under
Env. (Protection) Act-1986 (CPCB)

● Recognised Schedule II
Env. Auditor (GPCB)

*** End of Report ***

● ZDHC Approved for
Wastewater Guidelines V2.2

● ISO 9001 / 14001 / 45001

TERMS AND CONDITIONS GOVERNING THE TEST REPORT ISSUED

1. Samples shall not drawn be by M/s. Pollucon Laboratories Pvt. Ltd., unless otherwise requested in writing or mentioned in official written form. The results shall be applicable only to the received sample as requested in official communication. Approval of the sample is neither inferred nor implied.
2. The test report shall not be reproduced/ revised/ amended in full or part or with any linkage to previous report reference without the written approval submitted to Approving Authority of M/s Pollucon Laboratories Pvt. Ltd.
3. The test report in full or part shall not be used for promotional or publicity purpose and in court of law without the written consent of M/s. Pollucon Laboratories Pvt. Ltd.
4. Perishable samples shall be destroyed after completion of testing, non perishable / others samples shall be destroyed after 7 Days from the date of issuance of the test report, unless otherwise agreed with the customer or as required by the applicable regulations.
5. Signature of Approving authority in hard copy of test report is mandatory. E-signature (digital) is not valid for the authorization of test report.
6. Any damage or loss due to the test report/the certificate is liable for invoice value only.